

## AMENDMENT 0003 OF SOLICITATION DAHA06-02-B-0002

### 1. INSURANCE- MINIMUM AMOUNTS

Reference the contract clause titled "Insurance- Work on a Government Installation" FAR 52.228-5, kinds and minimum amounts are as follows:

<u>KIND</u>	<u>AMOUNTS</u>
Workmen's Compensation	\$100,000 (1)
Comprehensive General Liability	\$500,000 per occurrence for bodily injury
Comprehensive Automobile Liability	\$200,00 per person and \$500,000 per accident for bodily injury, and \$20,000 for property damage
Aircraft Public and Passenger Liability (if applicable)	\$200,000 per person and \$500,000 per occurrence for bodily injury, other than passenger liability, and \$200,000 per occurrence for property damage, coverage for passenger liability bodily injury shall be at least \$200,000 multiplied by the number of seats or passengers whichever is greater.

- (1) Except in States with exclusive or monopolistic funds that do not permit workers compensation to be written by private carriers.

NOTE: Before commencing work under this contract, the Contractor shall certify to the Contracting Officer in writing that the required insurance has been obtained. The policies evidencing required insurance shall contain an endorsement to the effect that any cancellation or any material change adversely affecting the Government's interest shall not be effective (1) for such period as the laws of the State in which this contract is to be performed prescribe, or (2) until 30 days after the insurer or the Contractor gives written notice to the Contracting Officer, whichever period is longer. The Contractor shall maintain a copy of all subcontractor proofs of required insurance and shall make copies available to the Contracting Officer.

2. Drawings A-1 and S-3 depict actual dimension of trench. There are 7 lines to be removed: three – 3", two 4", one – 1½", and one – ¾". All seven pipes are presumed to be insulated with ACM. The trench is sand filled. No profile has been done. Contractor is required to sample. See Drawings C1 and C-4.
3. ANG ETL 01-1 (Design Policy) and AF ETL 01-2 (Fire Protection) referenced in Specification Section 13900, Para 1.1/B is attached.
4. Drawing FP-3 is amended as follows: All fire protection piping except eight (8) inches have been removed and is deleted from this contract.